

# Julabo Case Study

## JULABO PRESTO® A40

Cool-down of a 10 liters reactor from  
+20 °C to maximum low temperature



### Objective

This case study tests the maximum low temperature of the Presto A40 with a 10 liters glass reactor. The A40 is connected to the reactor via 2.0 m metal tubings. The A40 is cooled-down from +20 °C to maximum low temperature.

### Test Conditions

JULABO unit	JULABO Presto A40
Cooling power	+20 °C 1.2 kW
	0 °C 0.9 kW
	-20 °C 0.6 kW
Heating capacity	2.7 kW
Band limit	No
Flow pressure	0.40 bar
Bath fluid	JULABO Thermal HL40
Reactor	10 liters glass reactor (Normag) filled with 10 liter JULABO Thermal HL40
Control	External (ICC)

### Environment

Room temperature	+20 °C
Humidity	45 %
Voltage	230 V / 50 Hz



### Test Results

See chart on back page: The A40 cooled the reactor from +20 °C down to maximum low temperature of -32 °C in 4 h.


### Tip

You can also use the robust Pt100 with PTFE coating.

More tips on  
back page >>



JULABO GmbH  
Eisenbahnstraße 45  
77960 Seelbach / Germany  
Tel. +49 (0) 7823 51-0




**Tip**

Make use of the option to regulate the pump pressure. You can define the desired pressure in the PRESTO® settings.



**Tip**

The Ethernet interface permits full access to all operational functions of the PRESTO®.



JULABO GmbH  
 Eisenbahnstraße 45  
 77960 Seelbach / Germany  
 Tel. +49 (0) 7823 51-0